

CERTIFICATE OF COMPLIANCE

Certificate Number 20120621-E210376
Report Reference E210376-20100817
Issue Date 2012-JUNE-21
Issued to: SMA SOLAR TECHNOLOGY AG
SONNENALLEE 1
34266 NIESTETAL GERMANY

This is to certify that representative samples of

STATIC INVERTERS, CONVERTERS AND ACCESSORIES FOR USE IN INDEPENDENT POWER SYSTEMS

See Addendum

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard for Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources, UL 1741, Second Edition. Standard for Interconnecting Distributed Resources with Electric Power Systems, IEEE 1547. Standard for Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems, IEEE 1547.1. Standard for General Use Power Supplies, CSA C22.2 No. 107.1-2001.

This description also includes a complementary Listed, integral Type 1 Photovoltaic DC Arc-Fault Circuit Interrupter Protection, Sunny Boy Cat nos. SB6000TLUS-12, SB7000TLUS-12, SB8000TLUS-12, SB9000TLUS-12, SB10000TLUS-12, SB11000TLUS-12. This Listing was evaluated for compliance with the applicable provisions of the Standard for Safety for Arc Fault Circuit Interrupters, UL 1699, Second Edition, including revisions dated February 11, 2011, and Outline of Investigation Subject 1699B, Photovoltaic (PV) DC Arc-Fault Circuit Protection, Issue Number 1, dated April 29, 2011.

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:

 the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20120621-E210376
Report Reference E210376-20100817
Issue Date 2012-JUNE-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Permanently connected, utility interactive, non-isolated (transformerless), inverters:

SMA Solar Technology AG Models: SB6000TL-US, SB7000TL-US, SB8000TL-US, SB9000TL-US, SB10000TL-US and SB11000TL-US inverters, which are intended for DC input from the following sources: photovoltaic modules from an ungrounded PV array.
Models may also be provided with suffix "-12."

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

